

<b>Basic unit</b>		
Trade name	Ensy	
Product name	<b>AHU-300BH</b> <b>AHU-300BV</b>	
ErP compliance	<b>2018</b>	
Unit category	<b>RVU</b>	
Unit type	<b>BVU</b>	
Drive	Variable speed	
Heat recovery type	Regenerative	
Thermal efficiency of HRS	<b>86</b> %	
$q_{Vd\ max}$	<b>258</b> m³/h	
$P_{tU}$	<b>100</b> Pa	
$P_{el,max}$	<b>224</b> W	
Sound power level L <sub>wa</sub>	<b>45</b> dB(A)	
$q_v\ ref$	<b>181</b> m³/h	
$P_{tU}\ ref$	<b>50</b> Pa	
Max external and Internal Leakage. Overpressure 250 Pa	<b>2.0</b> %	
Max external and Internal Leakage. Underpressure 250 Pa	<b>2.0</b> %	
Annual operation hours t <sub>a</sub>	<b>8760</b> h/a	
Primary energy factor pef	<b>2,5</b>	
Net ventilation rate q <sub>net</sub>	<b>1,3</b> m³/hm²	
MISC (ducted)	<b>1,1</b>	
CTRL (local demand)	<b>0,65</b>	
X value. Motor drive characteristic (Variable speed)	<b>2</b>	
SPI Specific power input (measurement)	<b>0,00036</b> kW/m³/h	
Total hours heating season t <sub>h</sub> Average	<b>5112</b> h/a	
Total hours heating season t <sub>h</sub> Cold	<b>6552</b> h/a	
Total hours heating season t <sub>h</sub> Warm	<b>4392</b> h/a	
Average temperature difference ΔT <sub>h</sub> Average	<b>9,5</b> K	
Average temperature difference ΔT <sub>h</sub> Cold	<b>14,5</b> K	
Average temperature difference ΔT <sub>h</sub> Warm	<b>5</b> K	
Thermal efficiency η <sub>h</sub>	<b>0,75</b>	
Specific heat capacity C <sub>air</sub>	<b>0,000344</b> kWh/m³K	
Reference natural ventilation rate q <sub>ref</sub>	<b>2,2</b> m³/hm³	
Thermal efficiency of HRS η <sub>t</sub>	<b>0,86</b>	

<b>Basic unit</b>		
Defrosting period $t_{defr}$ Average	<b>168</b>	h/a
Defrosting period $t_{defr}$ Cold	<b>1003</b>	h/a
Defrosting period $t_{defr}$ Warm	<b>0</b>	h/a
Average temperature difference defrost $\Delta T_{defr}$ Average	<b>2,4</b>	K
Average temperature difference defrost $\Delta T_{defr}$ Cold	<b>5,2</b>	K
Average temperature difference defrost $\Delta T_{defr}$ Warm	<b>0</b>	K
AEC average. Annual electrical consumption per 100 m <sup>2</sup>	<b>190.5</b>	kWh/a
AEC cold	<b>190.5</b>	kWh/a
AEC warm	<b>190.5</b>	kWh/a
AHS Average. Annual heating saved per m <sup>2</sup>	<b>46.1</b>	kWh/a
AHS Cold	<b>90.2</b>	kWh/a
AHS Warm	<b>20.8</b>	kWh/a
SEC Average. Specific energy consumption	<b>-41.3</b>	kWh/m <sup>2</sup> a
SEC Cold	<b>-85.4</b>	kWh/m <sup>2</sup> a
SEC Warm	<b>-16.1</b>	kWh/m <sup>2</sup> a
Efficiency Class	<b>A</b>	